

PIMPRI CHINCHWAD MUNICIPAL CORPORATION



(W/S) DIVISION

Report Of Chemical Examination Of Water

NO-WS / LAB 2524/2024

DATE - 16 / 03 / 2024

DATE OF RECEIPT - 14 / 03 / 2024

DATE OF EXAMINATION - 15 / 03 / 20 24


NAME - काकात्र इन्ड्रेशननल स्कुल

ADDRESS - रहारणी

SOURCE Pcmc water

NO	TESTS	I.S Standards for Drinking Water	Result mg/lit	Result mg/lit	Conclusion
1	Turbidity	1 N.T.U Max	1.69 NTU		
2	pH	6.5 to 8.5	6.74		
3	Total Hardness (as CaCO3)	200 mg/lit	56 mg/lit		
4	Chloride	250 mg/lit	14 mg/lit		
5	Calcium	75 mg/lit	12.82 mg/lit		

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY


CHIEF CHEMIST
Water treatment plant
sector 23 Nigdi