



पिंपरी चिंचवड महानगरपालिका  
अग्निशमन विभाग  
Pimpri Chinchwad Municipal Corporation  
Fire Department.



File No:-

1049

O.W.No:- Fire /01/5SP/ WS /1049 /2024.

Date:- 04 /10/2024

### FIRE SAFETY CERTIFICATE

Token No:- 103324250001875

Token Dt:- 02/05/2024

"M/S. "The Kaka's International School" Sr. No.70/1, Rahatani, Tapkirnagar, Kalewadi, Pune-411017.  
has applied for Fire Safety Certificate.

The Fire Officer has visited the school inspected the Fire Protection System installed at site and as per his technical remarks this NOC is being issued subject to compliance of following conditions.

- 1) The entire fire protection system installed at the site should be maintained in excellent working condition for the any fire emergency.
- 2) The fire extinguishers handling and operational training to be imparted to the teaching/non-teaching/security staff of the school.
- 3) You will carry out testing, maintenance and refilling of all fire extinguishers/fire protection systems from competent person (Govt. Fire Licensed Agency) and necessary Form-'A' Certificate regarding the maintenance and operational condition of the Fire Fighting system to be submitted to the Fire Office as per the Sec.3 (3) of the Fire Act.2016, for every six months in month of January to July, failing of which this NOC shall be treated as cancelled.
- 4) You will keep all the Static Water Tanks full for any fire emergency.
- 5) Fire/Emergency Evacuation Mock Drill should be carried out in the school once in every six months.
- 6) You will keep all passages and corridors free from any obstructions and combustible material.
- 7) "No Smoking Boards" "Emergency Exit" "Assembly Area" and "Emergency Contact Numbers Boards" of Fire, Ambulance, Police, MSEB, shall be always displayed in School to avoid/minimize fire/emergency situation/risk.
- 8) You have to keep fire protection system (fire extinguishers) easily accessible and visible as well as healthy and good working condition.
- 9) You have to install a Safety Net in the Staircase duct and school building construction site in the safety point of view.
- 10) This NOC is issued only from the fire safety point of view. It cannot be treated for any other purposes. However necessary permission from the statutory authorities should be obtained.
- 11) You are not permitted to construct the school building's remaining floors in the school working hours.
- 12) All the rules, regulations declared time to time from the PCMC or Govt. of Maharashtra shall be binding on you and any violation of these shall be viewed seriously.
- 13) This School Operational (Utility) Fire NOC is issued with respect to the Final Fire NOC No. Fire/1/RC/WS/1017/2024 Dt.27/09/2024 of Fire Dept. PCMC for Only Height-15.65 Mtrs, with Built up Area-915.12 Sq. mtrs And Gross Built up Area-1671.71 Sq. Mtrs. the terms and condition must be strictly fulfilled mentioned in above mentioned final fire NOC.
- 14) This Fire NOC is valid up to Dt. 29 Sep 2025 only and renewal of these NOC should be done every year before above mentioned date.

Fire Officer  
Pimpri Chinchwad Municipal Corporation  
Pimpri-18

To,

"M/S. "Kaka's International School"