



PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(W/S) DIVISION

REPORT OF CHEMICAL EXAMINATION OF WATER

NAME - द काकाजू इंटरनॅशनल स्कूल

ADDRESS - रहाटणी, काळेवाडी.

SOURCE - PCMC Water.

No-WS/LAB/996/2025.

Date - 07 / 03 /2025.

Date of Receipt - 06 / 03 /2025.

Date of Examination - 07 / 03 /2025

Sr.No.	Tests	I. S Standards for Drinking Water	Result mg/lit	Result mg/lit	Conclusion
1	Turbidity	1 N. T. U. Max	1.74 NTU		
2	pH	6.5 to 8.5	6.91		
3	Total Hardness (as CaCO ₃)	200 mg/lit	40 mg/lit		
4	Chloride	250 mg/lit	18 mg/lit		
5	Calcium	75 mg/lit	14.42 mg/lit		

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY

CHIEF CHEMIST

WATER TREATMENT PLANT, NIGDI, PCMC